

eddi zaehleranlagen.de GmbH

DECLARATION OF CONFORMITY
eddi zaehleranlagen.de GmbH
71554 Weissach im Tal



SURGE ARRESTOR

Type/types: **(1) TRS50**
(2) TRS100

Trade mark:



Basic parameters: (1)Un:230/240V; UC: 275V; Iin: 20kA; I_{max} 40kA
(2)Un:230/240V; UC: 275V; Iin: 30kA; I_{max} 50kA

Basic Parameters: Un:240V; UC (L1-N, N-PE) 300V/305V
I_{in} (L1-N, N-PE) 20kA/80kA
I_{max} (L1-N, N-PE) 50kA/100kA

is in conformity with the provisions of the following EC directive(s)
(including all applicable amendments):

Directive (LVD) - 2006/95/EC

Directive (RoHS) - 2011/65/EC

references of standard and/or technical specifications applied for this declaration of conformity:

EN 6164311:2012

EN 50581:2012

Additional information:

the certification carried out by:

Ente Certificazione Macchine Srl

Via Ca' Bella,243-Loc. Castello di Serravalle- 40053 Valsamoggia (Bo)-Italy

No. 0B171012.EZDTT99

Test Reports no. SCC(17)-50009A-29-10-LVD



is a registered trademark of Mr. Norbert Ebert, Weissach im Tal - Deutschland

Weissach im Tal, 23. Mai 2017

.....
Geschäftsführer

eddi zaehleranlagen.de GmbH
Mühlweg 32, 71554 Weissach im Tal
Tel: 07191-58603, Fax: 07191-58698
E-Mail: info@zaehleranlagen.de

Amtsgericht Stuttgart HRB 271935
Geschäftsführer: Norbert Ebert
UST-ID: DE 246 326 395